



#### POINT-TO-POINT NOTES

- 1 TAG CABLE WITH CODE AND NUMBER SPECIFIC TO THIS POINT PER PLAN AND SCHEDULE. TAG INDIVIDUAL WIRES AS SHOWN. REFERENCE STANDARD CRITERIA DRAWING SECURITY WIRE FORMAT.
- 2 LEAVE 20' SERVICE LOOP FOR CONNECTIONS TO DOOR BOARD, PIEZO & SIREN, AND LOCK HARDWARE.

**BA-3**

DOUBLE DOOR, CARD IN/FREE EXIT  
ELECTRIC LOCKSET w/REX SWITCH  
LOCAL NOISE (SIREN & PIEZO), 24VDC FAIL SECURE  
POINT-TO-POINT

SCALE: N.T.S.

LBNL ELECTRICAL STANDARDS

SECURITY CARD ACCESS BA-3

DOUBLE DOOR, CARD IN/FREE EXIT ELECTRIC LOCKSET

NTS

UNIVERSITY OF CALIFORNIA LAWRENCE BERKELEY NATIONAL LABORATORY

FACILITIES DIVISION

SEC103A

BA-3